

Short Form Classification Report No. 18043F

PRODUCT

Lexan™ Thermoclear™

SPONSOR

SABIC Innovative Plastics B.V.

PRODUCT DETAILS

- Thickness: 4 mm – 32 mm
- Surface mass: 800 g/m² – 3800 g/m²
- Coatings: Standard UV, SUN XP and Drippard
- No use of fire retardants
- Colours: All colours with an organic pigmentation between 0,000 % (Transparent) and 0,386 % (Soft lite)
- Structure: 2- to 9-wall tunnel / rectangular / X-structure

FIELD OF APPLICATION

- Freestanding
- With edge finishing of Euroclass A1 or A2 (protection of cut edges)
- Without joints

CLASSIFICATION

B-s1,d0

STANDARDS

Test standards: EN ISO 11925-2 (2002 & 2010/AC:2011) & EN 13823 (2002 & 2010+A1:2014)

Classification standard: EN 13501-1-2007+A1:2009

SIGNED

APPROVED

For and on behalf of WFRGENT nv

This short form classification report has been drafted according to EGOLF agreement EGA 08rev2:2013 "Application note: clause 5.10 [5.10/1] – Types of test reports used in fire testing". Whilst the test data and classification provided within this short form report was obtained in a test conducted fully in accordance with the standards EN ISO 11925-2 (2002 & 2010/AC:2011), EN 13823 (2002 & 2010+A1:2014) and EN 13501-1-2007+A1:2009, the presentation of the results in this short form report may not satisfy the requirements of those standards and EN ISO/IEC 17025:2005/AC:2006. The presentation of the results in this manner is made by agreement with the sponsor and use of the information herein for product assessment, approval or certification purposes will be restricted.

The full classification report No. **18043D** is available at **SABIC Innovative Plastics B.V.**

This document is the original version of this report and is written in English. This document may be used only literally and completely for publications. For publications of certain texts, in which this document is mentioned, our permission must be obtained in advance. The authenticity of the electronic signatures is assured by Belgium Root CA.